

Declaration of Hygiene Conformity

Ceiling Swirl Diffusers Types FD, RFD and FDE

Object of the inspection

TROX GmbH, Heinrich-Trox-Platz, D-47504 Neukirchen-Vluyn, Germany, hereby confirm that the ceiling swirl diffusers of types FD, RFD and FDE meet the hygiene requirements specified by the standards and regulations listed below.

- European standard
– EN 13779 (09/2007)
- German standards
– VDI 6022, part 1 (07/2011)
– VDI 3803 (02/2010)
- Austrian standards
– ÖNORM H 6021 (09/2003)
- Swiss SWKI regulations
– VA104-01 (04/2006)

For the purpose of this declaration of conformity a sample of each type mentioned above was viewed at the TROX GmbH factory, Heinrich-Trox-Platz, 47504 Neukirchen-Vluyn, Germany, and related data sheets, technical literature, and inspection reports were appraised.

Summary of the test result

The examination of the above-mentioned sample equipment and the appraisal of the available documents have shown that the hygiene requirements specified by the above-mentioned standards and regulations are met.

We hereby confirm that the ceiling swirl diffusers of types FD, RFD and FDE meet the hygiene requirements of the specified standards and regulations.

Neukirchen-Vluyn, Germany, 08 January 2015

Dipl.-Ing. Dirk Scherder
trained according to VDI 6022, category A
Product Management



Dipl.-Ing. Jan Heymann

Manager Quality Systems

Certificate